



Customer: Central States Diesel Generators STK#2262  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5396  
 Test Date 5/14/2018

Engine Make/ Model: Cummins QSL9-G3 NR3  
 Engine Spec/ Serial: 46947527  
 Unit Make/ Model: Onan DQDAA-7255929  
 Unit Spec/ Serial: J080214238

Voltage: 277/480  
 Amperage: 376  
 Kilowatts: 250  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	146.6	146.8	147.1	147.3	147.6	147.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	485	485	485	485
PH2	484	485	484	485	484	484
PH3	485	484	484	485	484	485
Amperage PH1	0	300	299	298	299	0
PH2	0	299	300	299	299	0
PH3	0	299	300	300	300	0
Kilowatts	0	251	251	251	251	0
Oil Pressure	62	58	57	57	57	60
Oil Temperature						
Coolant Temperature	180°F	188°F	189°F	189°F	189°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	52°F	52°F	52°F	53°F	53°F	53°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_