



Customer: Central States Diesel Generators STK#2264  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5346  
 Test Date 5/23/2018

Engine Make/ Model: Perkins ENGLAND 179671500  
 Engine Spec/ Serial: AH50798 U500 861H  
 Unit Make/ Model: Caterpillar D75-P3  
 Unit Spec/ Serial: NPF00588

Voltage: 277/480  
 Amperage: 91  
 Kilowatts: 75  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour							Cool Down
Eng Hours	243	243.3	243.5	243.8	244							244.1
Hertz/Cycles	60	60	60	60	60							60
Voltage PH1	480	480	480	481	481							480
PH2	481	481	480	480	481							481
PH3	480	480	481	482	481							480
Amperage PH1	0	90	91	91	90							0
PH2	0	90	90	91	90							0
PH3	0	91	91	90	90							0
Kilowatts	0	75	75	75	75							0
Oil Pressure	45	44	44	43	43							44
Oil Temperature												
Coolant Temperature	180°F	190°F	190°F	190°F	190°F							180°F
Man Vac./Press. L/B												
Man Vac./Press. R/B												
L/B Exhaust Temp												
R/B Exhaust Temp												
Exhaust Temperature												
DC Voltage	13.5	13.5	13.5	13.5	13.5							13.5
Natural Gas Pressure												
Diesel Fuel Level												
Room Temperature												
Ambient Temperature	75°F	75°F	76°F	76°F	76°F							76°F

Cable Length: \_\_\_\_\_ Cable/ Leg: \_\_\_\_\_ Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_