



Customer: Central States Diesel Generators STK#2265
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5339
 Test Date 5/7/2018

Engine Make/ Model: Perkins 1106D-E66TA 2682/1800
 Engine Spec/ Serial: PJ38418*U018443S
 Unit Make/ Model: Altorfer APS150
 Unit Spec/ Serial: 4159

Voltage: 277/480
 Amperage: 225
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	205.8	206	206.3	206.5	206.8	206.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	485
PH2	480	480	480	480	481	485
PH3	479	478	479	478	479	485
Amperage PH1	0	181	180	180	181	0
PH2	0	182	182	181	182	0
PH3	0	180	181	180	180	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	65	59	57	57	57	60
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	195°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	73°F	73°F	73°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____