



Customer: Central States Diesel Generators STK#2266
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5386
 Test Date 5/14/2018

Engine Make/ Model: Cummins QSB7G3 NR3
 Engine Spec/ Serial: 73567070
 Unit Make/ Model: Onan DSGAC-1335699
 Unit Spec/ Serial: H130553697

Voltage: 277/480
 Amperage: 225
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	406.9	407.1	407.4	407.6	407.9	408
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	484	484	484	483
PH2	484	483	483	483	483	484
PH3	483	484	484	484	483	483
Amperage PH1	0	180	180	180	180	0
PH2	0	181	180	180	181	0
PH3	0	180	181	180	180	0
Kilowatts	0	151	151	151	151	0
Oil Pressure	45	43	42	42	42	43
Oil Temperature						
Coolant Temperature	180°F	181°F	182°F	182°F	182°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	76°F	76°F	76°F	77°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____