



Customer: Central States Diesel Generators STK#2267  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5374  
 Test Date 5/14/2018

Engine Make/ Model: QSB7-G6 NR4  
 Engine Spec/ Serial: 73376669  
 Unit Make/ Model: Doosan G240  
 Unit Spec/ Serial: 437710UCWE51

Voltage: MULTIPLE  
 Amperage: MULTIPLE  
 Kilowatts: 190  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	5006.7	5006.9	5007.2	5007.4	5007.7	5007.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	481	481	481	480
PH2	481	481	480	480	480	481
PH3	480	481	481	481	481	480
Amperage PH1	0	230	229	229	229	0
PH2	0	229	229	230	229	0
PH3	0	229	230	230	230	0
Kilowatts	0	191	191	191	191	0
Oil Pressure	50	48	45	45	45	47
Oil Temperature						
Coolant Temperature	185°F	195°F	198°F	198°F	198°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	76°F	76°F	77°F	77°F	77°F	78°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_