



Customer: Central States Diesel Generators STK#2268
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5399
 Test Date 5/29/2018

Engine Make/ Model: Cummins KTA50-G9
 Engine Spec/ Serial: 33158057
 Unit Make/ Model: Cummins DFLE-5696590
 Unit Spec/ Serial: K040716754

Voltage: 277/480
 Amperage: 1804
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	575.3	575.5	575.8	576	576.3	576.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	480	480	480	481	480	480
Amperage PH1	0	1808	1802	1802	1802	0
PH2	0	1803	1805	1808	1807	0
PH3	0	1802	1805	1805	1804	0
Kilowatts	0	1501	1501	1503	1501	0
Oil Pressure	70	65	65	65	65	68
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	195°F	195°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	86°F	86°F	86°F	86°F	86°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____