



Customer: Central States Diesel Generators STK#2269
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5376
 Test Date 5/22/2018

Engine Make/ Model: Mitsubishi 6D24
 Engine Spec/ Serial: 368416
 Unit Make/ Model: Generator 5517650100
 Unit Spec/ Serial: 2084242

Voltage: 277/480
 Amperage: 277
 Kilowatts: 230
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	455.7	455.9	456.2	456.4	456.7	456.8
Hertz/Cycles	61	61	61	61	61	61
Voltage PH1	482	481	481	481	481	480
PH2	481	482	481	482	481	481
PH3	480	481	481	481	481	480
Amperage PH1	0	277	276	276	277	0
PH2	0	276	277	276	276	0
PH3	0	276	276	276	276	0
Kilowatts	0	230	230	230	230	0
Oil Pressure	50	48	48	48	48	48
Oil Temperature						
Coolant Temperature	170°F	170°F	170°F	170°F	170°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	62°F	62°F	63°F	63°F	63°F	63°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____