



Customer: Central States Diesel Generators STK#2270
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5807
 Test Date 8/14/2018

Engine Make/ Model: Cummins 4BT3.9-G2
 Engine Spec/ Serial: 45077858
 Unit Make/ Model: Cummins 60DGCB
 Unit Spec/ Serial: J940557181

Voltage: 277/480
 Amperage: 91
 Kilowatts: 60
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	490.1	490.3	490.6	490.8	491.1	491.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	481	481
PH2	481	482	481	481	480	481
PH3	482	482	481	482	482	482
Amperage PH1	0	72	72	72	71	0
PH2	0	71	73	72	73	0
PH3	0	73	71	73	72	0
Kilowatts	0	60	60	60	60	0
Oil Pressure	65	60	60	60	60	62
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	88°F	88°F	88°F	88°F	88°F	88°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____