



Customer: Central States Diesel Generators STK#2271
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5808
 Test Date 8/14/2018

Engine Make/ Model: Cummins 6CTA8.3-G2
 Engine Spec/ Serial: 45996604
 Unit Make/ Model: Cummins DGFA-4483225
 Unit Spec/ Serial: F000117146

Voltage: 277/480
 Amperage: 180
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	255.3	255.5	255.8	256	256.3	256.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	481	481
PH2	481	482	481	481	480	481
PH3	482	482	481	482	482	482
Amperage PH1	0	180	180	180	180	0
PH2	0	180	181	180	181	0
PH3	0	181	180	180	180	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	60	55	54	54	54	55
Oil Temperature						
Coolant Temperature	185°F	210°F	210°F	210°F	210°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	87°F	87°F	87°F	88°F	88°F	88°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____