



Customer: Central States Diesel Generators (#2273)
 Address: 530 Santa Rosa Dr.
 City/ State/ Zip Des Plaines, IL 60018
 Contact: Patrick Paden
 Phone: _____

R#: 5435
 Test Date 2018.06.12

Engine Make/ Model: Ford WSG1068
 Engine Spec/ Serial: 04QS35837
 Unit Make/ Model: Generac 4547640100
 Unit Spec/ Serial: 2079915

Voltage: 120/ 240
 Amperage: _____
 Kilowatts: 70
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	137.2	137.4	137.6	137.8	138.0	138.0
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	240	240	240	240	240
PH2	N/A	N/A	N/A	N/A	N/A	N/A
PH3	240	240	240	240	240	240
Amperage PH1	291	291	291	291	291	0
PH2	N/A	N/A	N/A	N/A	N/A	N/A
PH3	291	291	291	291	291	0
Kilowatts	70	70	70	70	70	0
Oil Pressure	55	55	55	55	55	52
Oil Temperature						
Coolant Temperature	156°F	180°F	190°F	190°F	190°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	80°F	80°F	80°F	80°F	80°F	80°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Rudy Sanchez

Customer Signature: _____