



Customer: Central States Diesel Generators STK#2275  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5443  
 Test Date 6/6/2018

Engine Make/ Model: Mitsubishi S12A2-PTA  
 Engine Spec/ Serial: 21593  
 Unit Make/ Model: Generac 573RSL4035  
 Unit Spec/ Serial: WA-516989-1098

Voltage: 277/480  
 Amperage: 962  
 Kilowatts: 800  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	444.4	444.6	444.9	445.1	445.4	445.5
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	481	481	480	481	481	481
PH2	479	480	479	480	479	480
PH3	481	480	481	481	480	481
Amperage PH1	0	962	961	962	960	0
PH2	0	960	961	963	962	0
PH3	0	961	962	961	961	0
Kilowatts	0	800	799	801	799	0
Oil Pressure	65	60	60	60	60	62
Oil Temperature						
Coolant Temperature	190°F	200°F	200°F	200°F	200°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	72°F	72°F	72°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_