



Customer: Central States Diesel Generators STK#2276  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5461  
 Test Date 6/13/2018

Engine Make/ Model: Detroit Diesel 08VF177874  
 Engine Spec/ Serial: 80837405  
 Unit Make/ Model: Stewart and Stevenson8V9230T35  
 Unit Spec/ Serial: 127154

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	262.8	263	263.3	263.5	263.8	263.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	477	476	475	476	475	477
PH2	476	475	476	475	476	476
PH3	476	475	475	476	475	476
Amperage PH1	0	423	424	425	426	0
PH2	0	424	423	424	424	0
PH3	0	424	425	424	423	0
Kilowatts	0	349	349	350	349	0
Oil Pressure	75	68	65	65	65	67
Oil Temperature						
Coolant Temperature	185°F	200°F	200°F	200°F	200°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	24.7	24.7	24.7	24.7	24.7	24.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	72°F	73°F	73°F	73°F

Cable Length: \_\_\_\_\_ Cable/ Leg: \_\_\_\_\_ Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_ Customer Signature: \_\_\_\_\_