



Customer: Central States Diesel Generators STK#2277
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5365
 Test Date 5/22/2018

Engine Make/ Model: Cummins NTA-855-G2
 Engine Spec/ Serial: 11907641
 Unit Make/ Model: Katolight D300FRZ4
 Unit Spec/ Serial: WA516951 51951

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	75.6	75.8	76.1	76.3	76.6	76.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	481	481	481	480
PH2	481	481	480	480	480	481
PH3	480	481	481	481	481	480
Amperage PH1	0	360	361	361	361	0
PH2	0	361	360	361	360	0
PH3	0	361	361	360	361	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	58	55	53	53	53	55
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	58°F	58°F	58°F	58°F	58°F	59°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____