



Customer: CEES - Used Equipment
 Address: _____
 City/ State/ Zip: _____
 Contact: _____
 Phone: _____

R#: 5316
 Test Date 5/22/2018

Engine Make/ Model: Cummins NTA-855-G2
 Engine Spec/ Serial: 30372908
 Unit Make/ Model: DFCB-5738270
 Unit Spec/ Serial: S/N: J050843819 SPEC: Z

Voltage: 480
 Amperage: 402
 Kilowatts: 335
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	349.1	349.3	349.5	349.8	350.1	350.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	385	385	385	385	385	0
PH2	385	385	385	385	385	0
PH3	395	393	392	393	392	0
Kilowatts	322	322	322	322	322	0
Oil Pressure	43	41	41	41	41	41
Oil Temperature						
Coolant Temperature	183°F	184°F	184°F	184°F	184°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.7	27.7	27.7
Natural Gas Pressure						
Diesel Fuel Level	REMOTE	REMOTE	REMOTE	REMOTE	REMOTE	REMOTE
Room Temperature						
Ambient Temperature						

Cable Length: 50

Cable/ Leg: 3

Connection Point: Breaker

Technician Signature: Edwards/ Sanchez

Customer Signature: _____