



Customer: Central States Diesel Generators STK#2282  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5726  
 Test Date 7/30/2018

Engine Make/ Model: Detroit 10637305  
 Engine Spec/ Serial: 06A0474311  
 Unit Make/ Model: Kohler 200ROZD  
 Unit Spec/ Serial: 393027

Voltage: 277/480  
 Amperage: 247  
 Kilowatts: 205  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	735	735.2	735.5	735.7	736	736.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	483	482	481	481	482
PH2	481	482	482	482	482	481
PH3	481	481	481	482	482	482
Amperage PH1	0	246	247	248	247	0
PH2	0	248	245	246	246	0
PH3	0	247	246	245	248	0
Kilowatts	0	205	205	205	205	0
Oil Pressure	50	45	45	44	44	45
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	74°F	74°F	74°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_