



Customer: Central States Diesel Generators STK#2284  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5498  
 Test Date 6/21/2018

Engine Make/ Model: Cummins LTA10-G1  
 Engine Spec/ Serial: 34982711  
 Unit Make/ Model: Cummins Onan DFAB-3381513  
 Unit Spec/ Serial: K990015011

Voltage: 120/208  
 Amperage: 639  
 Kilowatts: 230  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	350.5	350.7	351	351.2	351.5	351.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	0	640	638	638	639	0
PH2	0	638	640	639	638	0
PH3	0	639	639	639	639	0
Kilowatts	0	230	230	230	230	0
Oil Pressure	42	36	35	35	35	41
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	66°F	66°F	67°F	67°F	67°F	67°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_