



Customer: Central States Diesel Generators STK#2287
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5433
 Test Date 6/5/2018

Engine Make/ Model: Detroit Diesel R0837K36 (8V2000-G80)
 Engine Spec/ Serial: 5312000402/ A 361677
 Unit Make/ Model: Kohler 450REOZD4
 Unit Spec/ Serial: 0643320 PA-19700

Voltage: 277/480
 Amperage: 677
 Kilowatts: 450
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	300.2	300.4	300.7	300.9	301.2	301.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	542	541	542	541	0
PH2	0	540	540	540	542	0
PH3	0	542	542	541	541	0
Kilowatts	0	451	450	450	451	0
Oil Pressure	50	48	46	45	45	47
Oil Temperature						
Coolant Temperature	185°F	190°F	195°F	195°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	71°F	71°F	71°F	71°F	71°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____