



Customer: Central States Diesel Generators STK#2288
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5494
 Test Date 6/21/2018

Engine Make/ Model: Cummins NT-855G-4
 Engine Spec/ Serial: 11623568
 Unit Make/ Model: Cummins Onan 200DFBC
 Unit Spec/ Serial: D910380253

Voltage: 277/480
 Amperage: 301
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	236.4	236.6	236.9	237.1	237.4	237.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	240	240	240	240	0
PH2	0	241	240	241	240	0
PH3	0	240	241	240	240	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	50	46	45	45	45	46
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	65°F	65°F	66°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____