



Customer: Central States Diesel Generators STK#2290
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5622
 Test Date 7/19/2018

Engine Make/ Model: Caterpillar 3516
 Engine Spec/ Serial: 1HZ01810
 Unit Make/ Model: Caterpillar 3516
 Unit Spec/ Serial: 1HZ01810

Voltage: 277/480
 Amperage: 2406
 Kilowatts: 2000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	394	394	394	394	395	395
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	482	483	482	483
PH2	485	484	483	483	482	485
PH3	483	484	483	483	484	483
Amperage PH1	0	2401	2400	2405	2403	0
PH2	0	2405	2406	2402	2403	0
PH3	0	2400	2402	2406	2402	0
Kilowatts	0	2000	2000	2000	2000	0
Oil Pressure	62	58	58	57	57	60
Oil Temperature						
Coolant Temperature	185°F	191°F	192°F	192°F	192°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	74°F	74°F	75°F	75°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____