



Customer: Central States Diesel Generators STK#2292
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5555
 Test Date 7/2/2018

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z21525
 Unit Make/ Model: Caterpillar SR4B
 Unit Spec/ Serial: 9FG01197

Voltage: 277/480
 Amperage: 902
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	556	556	556	556	557	557
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	480	479	480
PH2	479	479	478	479	478	479
PH3	477	477	477	477	477	477
Amperage PH1	0	725	723	725	723	0
PH2	0	723	724	724	724	0
PH3	0	724	724	723	724	0
Kilowatts	0	600	599	600	599	0
Oil Pressure	70	68	68	67	67	69
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	195°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	74°F	75°F	75°F	75°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____