



Customer: Central States Diesel Generators STK#2294
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5593
 Test Date 7/3/2018

Engine Make/ Model: Detroit Diesel R1237K35
 Engine Spec/ Serial: Spec A 361565 5352000682
 Unit Make/ Model: Kohler 600R0ZD4
 Unit Spec/ Serial: 661570

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	403.7	403.9	404.2	404.4	404.7	404.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	476	475	475	476	480
PH2	481	475	476	475	475	481
PH3	480	476	475	476	475	480
Amperage PH1	0	725	725	725	724	0
PH2	0	724	723	724	725	0
PH3	0	725	724	724	723	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	125	120	120	120	120	120
Oil Temperature						
Coolant Temperature	175°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	78°F	78°F	78°F	79°F	79°F	79°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____