



Customer: Central States Diesel Generators STK#2295
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5558
 Test Date 7/2/2018

Engine Make/ Model: Cummins 6CTA8.3G2
 Engine Spec/ Serial: 46301922
 Unit Make/ Model: Cummins DGFA-5602614
 Unit Spec/ Serial: D030489521 P

Voltage: 120/240
 Amperage: 625
 Kilowatts: 150
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	613.6	613.8	614.1	614.3	614.6	614.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	240	240	240	240	240
PH2	120	120	120	120	120	120
PH3	120	150	120	120	120	120
Amperage PH1	0	625	624	624	624	0
PH2	0	625	626	625	624	0
PH3	0	625	625	624	625	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	48	46	45	45	45	43
Oil Temperature						
Coolant Temperature	182°F	190°F	190°F	190°F	190°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	80°F	80°F	80°F	80°F	80°F	80°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____