



Customer: Central States Diesel Generators STK#2299
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5639
 Test Date 7/13/2018

Engine Make/ Model: John Deere 4045HF285
 Engine Spec/ Serial: PE4045L124897
 Unit Make/ Model: Baldor TS130-3J
 Unit Spec/ Serial: P1006090010

Voltage: 208
 Amperage: 347
 Kilowatts: 101
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	379.7	379.9	380.2	380.4	380.7	380.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	209	209	209	208	209
PH2	208	209	210	209	209	208
PH3	208	208	209	208	209	208
Amperage PH1	0	280	280	280	279	0
PH2	0	281	279	279	280	0
PH3	0	280	280	279	280	0
Kilowatts	0	101	101	101	101	0
Oil Pressure	50	48	46	46	46	47
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	12.1	12.1	12.1	12.1	12.1	12.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	90°F	90°F	90°F	90°F	91°F	91°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____