



Customer: Central States Diesel Generators STK#2300
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5599
 Test Date 7/3/2018

Engine Make/ Model: Caterpillar 3456
 Engine Spec/ Serial: 7WG03186
 Unit Make/ Model: Caterpillar LC6
 Unit Spec/ Serial: G6B00818

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	92	92	92	92	93	93
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	478	476	475	476	475	478
PH2	480	475	476	475	475	480
PH3	479	476	475	477	476	479
Amperage PH1	0	421	422	421	420	0
PH2	0	420	421	420	421	0
PH3	0	421	421	422	422	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	70	67	67	67	66	68
Oil Temperature						
Coolant Temperature	185°F	194°F	194°F	194°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____