



Customer: Central States Diesel Generators STK#2302
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5641
 Test Date 7/17/2018

Engine Make/ Model: John Deere 6068TF250
 Engine Spec/ Serial: PE6068T109455
 Unit Make/ Model: D125FJJ4
 Unit Spec/ Serial: LM641565

Voltage: 120/240
 Amperage: 375
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	313.1	313.3	313.6	313.8	314.1	314.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	241	240	241	241	240	241
PH2	240	241	241	240	241	240
PH3	241	241	240	240	241	241
Amperage PH1	0	300	301	299	300	0
PH2	0	299	300	300	301	0
PH3	0	301	300	299	301	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	55	53	53	52	52	53
Oil Temperature						
Coolant Temperature	190°F	1200°F	202°F	205°F	205°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	86°F	86°F	86°F	87°F	87°F	87°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____