



Shop Order Inquiry Report - Shop Order Detail

General Shop Order Data

Loc- SO# - Sfx#	Item Number	Description	Std Lab Hours	Act Lab Hours	Type	Status
01 - 9102 - 0	800540	D125F*J4/D105F*J5	38.10	64.41	Productive	Completed

Shop Order Header

Shop Order	Start Date	Due Date	Complete Date	Last Changed Date	Qty Ordered
9102	2/20/2001	3/9/2001	3/21/2001	3/21/2001	1

Shop Order Jobs

Job Number	Sequence	Split Percentage	Reference	Cost Category
71445	5	100.00	071445-00/0005	50

Shop Order Notes

Sequence	Notes
1	48 HR NOTICE B-4 DEL. HECTOR
2	213-483-1470
3	PROCESSED BY MATT 2-8-01, UNIT WIRING DWGS AC 819-B-7702, DC 819-C-4515, PP 819-B-7781
4	RPM: 1800
5	KW: 125.0
6	KVA: 156.0
7	FREQ: 60
8	PF: .8
9	TEMP RISE RATING: NEMA
10	STANDARD UNIT
11	JOHN DEERE 6068T 12V RCLR, Serial # PE6068T109455
12	VOLTAGE: 240 3 PHASE
13	363PSL1607 SE350 3&11.5 12W, Serial # LM-641565-0201
14	STD 50K CONTROL PANEL 12V
15	CONTROL PANEL UNIT MOUNTED
16	AMMETER 0-500
17	VOLTMETER 0-300/0-600 240VAC
18	FREQUENCY METER 55-65HZ
19	CURRENT TRANSFORMER 500A 3X
20	STD ELECT GOVERNOR ADD-ON, ESD2210/ADC100
21	ENCLOSURE 300 SERIES, HSG-304
22	LOUVER 300 SERIES ENCLOSURE
23	CONTROL PANEL MOUNTED LSFG, DIM DWG 100-1120
24	STD STEEL BASE HSD FORMED, BASE DWG 102-2156-A



- 25 COOLING SYSTEM STANDARD
- 26 LOW WATER LEVEL SWITCH ONLY
- 27 BREAKER 400A 3P 240V W/ENC
- 28 400AF BKR MTD RIGHT SIDE
- 29 STD BATTERY, RACK, & ACID
- 30 WATER HEATER 1000W 120VAC, KIM TPS101
- 31 HEATER NOT WIRED TO TERMINAL
- 32 SPECIFY VIBRATION ISOLATORS
- 33 SPRING ISOLATORS TJC-1430 6X
- 34 OIL DRAIN EXTENSION REQUIRED
- 35 AE1210 BATTERY CHARGER
- 36 CHARGER MOUNTED & DC WIRED
- 37 CRITICAL GRADE EXHAUST
- 38 EXH CRITICAL GRADE HSD
- 39 EXHAUST FLEX HOUSED, DWG 105-1522-15
- 40 FUEL SYS DIESEL W/FUEL TANK
- 41 SPECIFY BASE TANK
- 42 TANK SB 230GL DW UL W/STUB-UP, DWG 108-008
- 43 110X46X18
- 44 LOW FUEL LEVEL SWITCH
- 45 NO TRAILER REQUIRED
- 46 SWITCHES & SENDERS 50K PANEL
- 47 UNIT TO BE PAINTED KL GOLD
- 48 1 O&M MANUAL SEND W/UNIT, ***LAMINATED INSTRUCTIONS***, ***02/21/01 QTY 1 VALLEY KVK
- 49 STANDARD COMMERCIAL TEST
- 50 UNIT TO SHIP WET
- 51 2 YEAR WARRANTY 1500HR LIMIT
- 52 ADDITIONAL REQUIRMENTS #1
- 53 ***OPERATING INSTRUCTIONS
- 54 UNDER PLEXI-GLASS***
- 55 COMM, FRGHT AND ECT APPLY

Shop Order Materials

Component	Seq	Description	Need Date	Notes
100151	0	COMPLETE CONTROL PANEL	2/20/2001	
31027	0	HANDLE "T" SMALL LOCKING W/CAM	2/20/2001	T-305 HANDLE# WITH CAM
32007	0	BREAKER CIR 400A 240V 3P	2/20/2001	TJD432400WL
34140	0	PROBE LOW WATER LEVEL	2/20/2001	DP1000 2 1/2
35070	0	SWITCH TEMP 55F 1/2 NPT NC	2/20/2001	
35098	0	SWITCH TEMP 215F 6A NO	2/20/2001	TT-F2A-215R
36907	0	MOUNT VIB SPRING 1430 LBS	2/20/2001	TJC-1430, SEND LOOSE
40506	0	BATTERY 12V 4D ENGINE STARTING	2/20/2001	
40511	0	RACK BATTERY UNIT MTD 23" OAL	2/20/2001	204-169



40668	0	ACID BATTERY 20QT CONTAINER	2/20/2001	
40709	0	BRACKET SUPPORT WIRE	2/20/2001	204-312-1
40717	0	BRACKET MUFFLER MTG 10"	2/20/2001	105-179-1
41051	0	VALVE CHECK 3/8" NPT STANDARD	2/20/2001	PARKER 2650
41270	0	CHARGER BATTERY 12V 10A 120VAC	2/20/2001	AE1210
41514	0	VALVE OIL DRAIN 18MM X 1 1/2"	2/20/2001	F-104-N
41709	0	TRANSFORMER CURRENT 500:5 600V	2/20/2001	
42239	0	CAP FUEL FILL 2" NPT FEMALE	2/20/2001	#179 2" FEMALE
42545	0	GUARD ALTERNATOR JD6068	2/20/2001	105-1489
42644	0	FLEX EXHAUST SS OAL 15"	2/20/2001	105-1522-15
42820	0	BLOCK FUSE 3P 600V	2/20/2001	
42828	0	FUSE 10A 600V JX6-10	2/20/2001	JX6-10
44321	0	CLAMP MUFFLER 3 1/2"	2/20/2001	P20-0585
44868	0	PLUG PIPE 3" NPT	2/20/2001	2-1576
44940	0	SENSOR SPEED MAGNETIC GAC	2/20/2001	MSP-6724
44982	0	ENCLOSURE BKR NEMA 1 TJ400S	2/20/2001	TJ400S
45205	0	CAP RAIN VERTICAL 4"	2/20/2001	WALKER #35907
45221	0	FLANGE ANGLE RING 6" I.D.	2/20/2001	
45900	0	SENDER GAUGE PRESSURE 0-100PSI	2/20/2001	411-K
45945	0	GAUGE LEVEL FUEL MECHANICAL	2/20/2001	6580-0015
45973	0	SENDER TEMP 100-240 DEG F	2/20/2001	334P
45986	0	ADAPTER GAUGE 2"NPT ZINC	2/20/2001	
46000	0	SOLENOID START 12VDC	2/20/2001	
46103	0	SWITCH LEVEL FLOAT .050A NO/NC	2/20/2001	N1000N
46110	0	SWITCH PRESSURE 20PSI 10A SPDT	2/20/2001	SM-2C-20F
46114	0	SWITCH TEMP 225F 6A NO 1/2NPT	2/20/2001	TT-F1A-225R/G
46115	0	SWITCH PRESSURE 15PSI 10A SPDT	2/20/2001	SM-2C-15F
46900	0	MOUNT VIBE 1 1/4" ISOPRENE W/	2/20/2001	310575I400
46906	0	MOUNT VIB PAD 2 X 10 X 1/4	2/20/2001	105-1661, MOUNT BETWEEN UNIT & TANK
47432	0	ELBOW PIPE 90 DEG 3 1/2"	2/20/2001	
47454	0	COUPLING PIPE 3 1/2"	2/20/2001	
47556	0	NIPPLE PIPE 1 1/2"NPT X 6" LG	2/20/2001	
47816	0	HARNESS WIRING 6068T	2/20/2001	818-114
48304	0	PLUG PIPE 1-1/2"NPT	2/20/2001	
48670	0	NIPPLE PIPE 2" NPT X 4" LG	2/20/2001	
50140	0	LOUVER FIXED 38W X 52H X 4D	2/20/2001	LOUVER HSG-304
50308	0	ENCLOSURE WEATHER PROOF	2/20/2001	HSG-304
52746	0	HEATER TANK 1000W 120AC	2/20/2001	TPS-101GT10-000
53433	0	GENERATOR 363/1607 SE350	2/20/2001	
54316	0	ACTUATOR GOVERNOR 12V GAC	2/20/2001	ADC100-12
55327	0	BRACKET CONTROL PANEL SIDE MTG	2/20/2001	105-1531
57074	0	NIPPLE PIPE 3 1/2" HALF	2/20/2001	
58423	0	HARNESS WIRING 6068T	2/20/2001	818-136



59258	0	TANK SB 230GL DW UL W/STUB-UP	2/20/2001	108-008
61055	0	MUFFLER 3 1/2" CRITICAL SI	2/20/2001	JCS35-1048
61251	0	COLLAR STORM 4"	2/20/2001	105-1121
69053	0	BRACKET ROOF SUPPORT	2/20/2001	105-1541
70380	0	HINGE TORPEDO LH JONES# H0090	2/20/2001	26808 AUSTIN
70381	0	HINGE TORPEDO RH JONES# H0095	2/20/2001	26809 AUSTIN
70670	0	FAN 24" BREEZA FAN #2	2/20/2001	24/160/10/30/GRP/RSPL
70687	0	ELBOW TUBING FLARED 3 1/2" 90	2/20/2001	105-1656
70692	0	FILTER AIR DONALDSON DURALITE	2/20/2001	RE63780, W/ RODENT SCREEN
70699	0	SPACER FAN JD 4045/6068 30-105	2/20/2001	S350001
70701	0	CLAMP V-BAND 4.21 CLAMP DIA	2/20/2001	VT10433K02-3ARB
70839	0	ADAPTER W/O-RING FOR JD ENGINE	2/20/2001	20-1 F50G-S
71117	0	MOUNT VIB PVC DONUT TYPE	2/20/2001	60525K23
71118	0	MOUNT VIB RUBBER SANDWICH TYPE	2/20/2001	1551-113
71119	0	BASE HSD FORMED 110"L X 46"W	2/20/2001	102-2156-A
71121	0	BRACKET RADIATOR SUPPORT UPPER	2/20/2001	105-1746
71125	0	BRACKET ENGINE SUPPORT RIGHT	2/20/2001	Order KL #71131 with #71125, 105-1750
71127	0	BRACKET GENERATOR CHANNEL	2/20/2001	105-1751
71131	0	BRACKET ENGINE SUPPORT LEFT	2/20/2001	Order KL #71125 w/#71131, 105-1755
71133	0	GUARD FAN 24" SPIRAL	2/20/2001	FG24
71165	0	GUARD BELT 4045 & 6068	2/20/2001	
71299	0	ELBOW HOSE REDUCING RUBBER	2/20/2001	
71304	0	HOSE RADIATOR UPPER	2/20/2001	
71305	0	HOSE RADIATOR LOWER	2/20/2001	CARQUEST #21379
72964	0	VENT TANK 1 1/2" MUSHROOM STYL	2/20/2001	
73208	0	PANEL RADIATOR CORE JOHN DEERE	2/20/2001	105-2039
73587	0	ENGINE 6068TF250 12V LESS RAD	2/20/2001	
73594	0	RADIATOR 25X25 5R11L LESS FG	2/20/2001	

Shop Order Operations

Operation	Department	Work Center	Status	Start Date	Due Date
5	22	01	Complete	2/19/2001	2/19/2001
10	26	01	Complete	3/1/2001	3/19/2001
20	26	01	Complete	3/1/2001	3/19/2001
31	26	01	Complete	3/1/2001	3/15/2001
40	26	01	Complete	3/1/2001	3/19/2001
51	26	01	Complete	3/1/2001	3/19/2001
61	26	01	Complete	3/1/2001	3/1/2001
70	26	01	Complete	3/1/2001	3/19/2001
80	26	01	Complete	3/1/2001	3/1/2001
90	26	01	Complete	3/1/2001	3/19/2001
102	26	01	Complete	3/1/2001	3/19/2001



120	26	01	Complete	3/1/2001	3/19/2001
130	26	01	Complete	3/1/2001	3/19/2001
142	26	01	Complete	2/28/2001	3/19/2001
161	26	01	Complete	3/1/2001	3/19/2001
175	26	01	Complete	3/1/2001	2/27/2001
180	28	01	Complete	3/2/2001	3/14/2001
190	30	01	Complete	3/5/2001	3/19/2001
200	30	01	Complete	3/5/2001	3/5/2001
210	32	01	Complete	3/6/2001	3/16/2001
213	26	01	Complete	3/7/2001	3/19/2001
215	34	01	Complete	3/21/2001	3/21/2001