



Customer: Central States Diesel Generators STK#2305
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5743
 Test Date 7/31/2018

Engine Make/ Model: Cummins QSM11-G4 NR3
 Engine Spec/ Serial: 35273476
 Unit Make/ Model: Cummins DQHAB-5229110
 Unit Spec/ Serial: H100146800

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1708.6	1708.8	1709.1	1709.3	1709.6	1709.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	479	480
PH2	479	480	479	480	480	479
PH3	480	480	480	480	480	480
Amperage PH1	0	361	360	360	361	0
PH2	0	361	362	361	360	0
PH3	0	360	361	361	362	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	37	33	33	33	33	35
Oil Temperature						
Coolant Temperature	180°F	183°F	184°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	71°F	71°F	71°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____