



Customer: Central States Diesel Generators STK#2310
 Address: 2001 S Prairie Avenue
 City/ State/ Zip: Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5935
 Test Date: 9-10-2018

Engine Make/ Model: Caterpillar 3406B
 Engine Spec/ Serial: 2WB05616
 Unit Make/ Model: Caterpillar SR-4
 Unit Spec/ Serial: 6BA02970

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	178	178	179	179	179	179
Hertz/Cycles	59.8	58.8	58.8	58.8	58.8	59.8
Voltage PH1	489	488	488	488	488	489
PH2	490	488	488	488	488	490
PH3	489	488	488	488	488	489
Amperage PH1	0	355	354	355	356	0
PH2	0	355	356	355	355	0
PH3	0	356	355	355	355	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	60	53	52	52	52	56
Oil Temperature						
Coolant Temperature	178°F	192°F	192°F	192°F	192°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26	26	26	26	26	26
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	74°F	74°F	74°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____