


Work Order

			
WO No.:	5346	Open / History:	H
WO Date:	05/11/2018	Job Status:	Completed
Sched. Date:	05/11/2018	Status Change Date:	2018.08.13 (I)
Completed Date:	08/14/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	PE-U500861H
CEES Quote:		Unit #:	2264
		Engine Make:	PERKINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	1796/1500
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	U500861H
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	OLYMPIAN
Zip:	53189	Unit Model No.:	D75P3
Requested By:	PATRICK PADEN	Unit Serial No.:	OLY00000HNP0588
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORSS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Load Bank	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
		Kilowatts:	
Customer Complaint:	REMOVE RADIATOR FOR REPAIR PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Voltage:	
		Cable Run (ft):	0
Work Performed:	5-11-18 REMOVED RADIATOR. 5-23-18 INSTALL REPAIRED RADIATOR. PERFORM 1 HOUR LOAD BANK TEST.		
Follow-Ups:			


Sales Order

08/14/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5346



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2264

Notes

REMOVED RADIATOR AND INSTALLED REPAIRED RADIATOR, PERFORMED 1HR LOAD BANK TEST


Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3 hr	\$ 330.00
2	Sale	OT/F/WI - NORMAL OVERTIME FIELD - WI	\$ 135.00	2.5 hr	\$ 337.50

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 667.50
Sales Tax: \$ 0.00
Total: \$ 667.50

Work Order

			
WO No.: 5443		Open / History: H	
WO Date: 06/12/2018		Job Status: Completed	
Sched. Date: 06/06/2018		Status Change Date: 2018.08.13 (INV)	
Completed Date: 08/14/2018		Assign To Type: Technician	
Bill With Work Order:		Assign To: (RANDY POOL)	
Follow Up From WO#: 0			
Customer P.O. No.:		Asset ID: MI-21593	
CEES Quote:		Unit #: 2275	
		Engine Make: MITSUBISHI	
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: S12A2-PTA	
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.: 21593	
City: WAUKESHA		Engine Spec:	
State: WISCONSIN		Unit Make: GENERAC	
Zip: 53189		Unit Model No.:	
Requested By: PATRICK PADEN		Unit Serial No.:	
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours: 0	
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS			
Account #: 1121		Round Trip Miles: 0	
Perform For Type: Customer		Tolls Paid: 0	
Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)			
		Time In:	
WO Type: Repair		Time Out:	
Problem Type: INSPECT AND LOAD BANK FOR SALE			
		Signed Signature:	
Brief Description: INSPECT AND LOAD BANK FOR SALE		Kilowatts:	
		Voltage:	
Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST		Cable Run (ft): 0	
Work Performed: 6-6-18 PERFORMED INSPECTION AND 1 HOUR LOAD BANK TEST.			
Follow-Ups:			



Customer: Central States Diesel Generators STK#2275
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5443
 Test Date 6/6/2018

Engine Make/ Model: Mitsubishi S12A2-PTA
 Engine Spec/ Serial: 21593
 Unit Make/ Model: Generac 573RSL4035
 Unit Spec/ Serial: WA-516989-1098

Voltage: 277/480
 Amperage: 962
 Kilowatts: 800
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	444.4	444.6	444.9	445.1	445.4	445.5
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	481	481	480	481	481	481
PH2	479	480	479	480	479	480
PH3	481	480	481	481	480	481
Amperage PH1	0	962	961	962	960	0
PH2	0	960	961	963	962	0
PH3	0	961	962	961	961	0
Kilowatts	0	800	799	801	799	0
Oil Pressure	65	60	60	60	60	62
Oil Temperature						
Coolant Temperature	190°F	200°F	200°F	200°F	200°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	72°F	72°F	72°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/14/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5443



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2275

Notes

PERFORMED INSPECTION AND 1 HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3 hr	\$ 330.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 330.00
Sales Tax: \$ 0.00
Total: \$ 330.00

Work Order

		<input checked="" type="checkbox"/>	
WO No.:	5726	Open / History:	H
WO Date:	08/06/2018	Job Status:	Completed
Sched. Date:	07/30/2018	Status Change Date:	2018.08.13 (INV)
Completed Date:	08/13/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	DD-06A0474311
CEES Quote:		Unit #:	2282
		Engine Make:	DETROIT DIESEL
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	10637305
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	06A0474311
City:	WAUKESHA	Engine Spec:	A 347092
State:	WISCONSIN	Unit Make:	KOHLER
Zip:	53189	Unit Model No.:	200ROZD
Requested By:	PATRICK PADEN	Unit Serial No.:	393027
Req. Telephone:		Unit Spec:	PA-132455
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	08/06/2018 04:01:00 PM
WO Type:	Load Bank	Time Out:	08/06/2018 04:01:00 PM
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Kilowatts:	205
Work Performed:	7-30-18 PERFORMED INSPECTION AND 1 HOUR LOAD BANK TEST.	Voltage:	480
		Cable Run (ft):	0
Follow-Ups:			



Customer: Central States Diesel Generators STK#2282
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5726
 Test Date 7/30/2018

Engine Make/ Model: Detroit 10637305
 Engine Spec/ Serial: 06A0474311
 Unit Make/ Model: Kohler 200ROZD
 Unit Spec/ Serial: 393027

Voltage: 277/480
 Amperage: 247
 Kilowatts: 205
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	735	735.2	735.5	735.7	736	736.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	483	482	481	481	482
PH2	481	482	482	482	482	481
PH3	481	481	481	482	482	482
Amperage PH1	0	246	247	248	247	0
PH2	0	248	245	246	246	0
PH3	0	247	246	245	248	0
Kilowatts	0	205	205	205	205	0
Oil Pressure	50	45	45	44	44	45
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	74°F	74°F	74°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/13/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5726



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2282

Notes

PERFORMED INSPECTION AND 1 HR LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2 hr	\$ 220.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 220.00
Sales Tax: \$ 0.00
Total: \$ 220.00

Work Order

		<input checked="" type="checkbox"/>
WO No.: 5727		Open / History: H
WO Date: 08/06/2018		Job Status: Completed
Sched. Date: 07/30/2018		Status Change Date: 2018.08.13 (INV)
Completed Date: 08/13/2018		Assign To Type: Technician
Bill With Work Order:		Assign To: (RANDY POOL)
Follow Up From WO#: 0		
Customer P.O. No.:		Asset ID: CA-81Z17203
CEES Quote:		Unit #: 2311
		Engine Make: CATERPILLAR
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: 3412
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.: 81Z17203
City: WAUKESHA		Engine Spec: 7W-7170
State: WISCONSIN		Unit Make: CATERPILLAR
Zip: 53189		Unit Model No.: SR4
Requested By: PATRICK PADEN		Unit Serial No.: 6FA09902
Req. Telephone:		Unit Spec: 5N-8670
Req. E-mail:		Engine Hours: 0
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS		
Account #: 1121		Round Trip Miles: 0
Perform For Type: Customer		Tolls Paid: 0
Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:
WO Type: Load Bank		Time Out:
Problem Type: INSPECT AND LOAD BANK FOR SALE		
		Signed Signature:
Brief Description: INSPECT AND LOAD BANK FOR SALE		Kilowatts: 600
		Voltage: 480
Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST		Cable Run (ft): 0
Work Performed: INSPECT UNIT; PERFORM 1-HOUR LOAD-BANK TEST		
Follow-Ups:		



Customer: Central States Diesel Generators STK#2311
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5727
 Test Date 7/30/2018

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z17203
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 81217203

Voltage: 277/480
 Amperage: 721
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	914	914	914	915	915	915
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	480	479	480
PH2	479	480	480	479	480	479
PH3	480	480	480	480	480	480
Amperage PH1	0	721	722	721	722	0
PH2	0	722	721	721	721	0
PH3	0	722	721	722	721	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	69	68	67	66	66	68
Oil Temperature						
Coolant Temperature	185°F	187°F	187°F	187°F	187°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	73°F	73°F	73°F	73°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/13/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5727



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2311

Notes

PERFORMED INSPECTION AND 1 HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3 hr	\$ 330.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 330.00
Sales Tax: \$ 0.00
Total: \$ 330.00

Work Order

		<input checked="" type="checkbox"/>	
WO No.:	5729	Open / History:	H
WO Date:	08/06/2018	Job Status:	Completed
Sched. Date:	07/30/2018	Status Change Date:	2018.08.13 (INV)
Completed Date:	08/13/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	CU-35237817
CEES Quote:		Unit #:	2304
		Engine Make:	CUMMINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	QSM11G4
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	35237817
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CUMMINS
Zip:	53189	Unit Model No.:	DQHAB-7229336
Requested By:	PATRICK PADEN	Unit Serial No.:	H080204389
Req. Telephone:		Unit Spec:	A
Req. E-mail:		Engine Hours:	438.70
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	08/06/2018 04:06:00 PM
WO Type:	Load Bank	Time Out:	08/06/2018 04:06:00 PM
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Kilowatts:	300
Work Performed:	7-30-18 PERFORMED INSPECTION AND 1 HOUR LOAD BANK TEST.	Voltage:	480
		Cable Run (ft):	0
Follow-Ups:			



Customer: Central States Diesel Generators STK#2304
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5729
 Test Date 7/30/2018

Engine Make/ Model: Cummins QSM11-G4 NR3
 Engine Spec/ Serial: 35237817
 Unit Make/ Model: Cummins DQHAB-7229336
 Unit Spec/ Serial: H080204389

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	437.6	437.8	438.1	438.3	438.6	438.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	479	480	480	479	480
PH2	480	480	479	480	480	480
PH3	480	480	480	479	479	480
Amperage PH1	0	360	361	362	361	0
PH2	0	362	360	361	360	0
PH3	0	361	362	361	362	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	40	37	36	36	36	36
Oil Temperature						
Coolant Temperature	180°F	183°F	183°F	183°F	183°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	76°F	76°F	77°F	77°F	77°F	77°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/13/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5729



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2304

Notes

PERFORMED INSPECTION AND 1 HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal:	\$ 275.00
Sales Tax:	\$ 0.00
Total:	\$ 275.00

Work Order

		<input checked="" type="checkbox"/>	
WO No.:	5743	Open / History:	H
WO Date:	08/13/2018	Job Status:	Completed
Sched. Date:	07/31/2018	Status Change Date:	2018.08.13 (INV)
Completed Date:	08/13/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	CU-35273476
CEES Quote:		Unit #:	2305
		Engine Make:	CUMMINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	QSM11G4 NR3
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	35273476
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CUMMINS/ ONAN
Zip:	53189	Unit Model No.:	DQHAB- 5229110
Requested By:	PATRICK PADEN	Unit Serial No.:	H100146800
Req. Telephone:		Unit Spec:	B
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Load Bank	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Kilowatts:	300
		Voltage:	480
Work Performed:	INSPECT UNIT; PERFORM LOAD-BANK TEST.	Cable Run (ft):	0
Follow-Ups:			



Customer: Central States Diesel Generators STK#2305
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5743
 Test Date 7/31/2018

Engine Make/ Model: Cummins QSM11-G4 NR3
 Engine Spec/ Serial: 35273476
 Unit Make/ Model: Cummins DQHAB-5229110
 Unit Spec/ Serial: H100146800

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1708.6	1708.8	1709.1	1709.3	1709.6	1709.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	479	480
PH2	479	480	479	480	480	479
PH3	480	480	480	480	480	480
Amperage PH1	0	361	360	360	361	0
PH2	0	361	362	361	360	0
PH3	0	360	361	361	362	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	37	33	33	33	33	35
Oil Temperature						
Coolant Temperature	180°F	183°F	184°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	71°F	71°F	71°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/13/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5743



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2305

Notes

PERFORM INSPECTION ON UNIT AND LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3 hr	\$ 330.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 330.00
Sales Tax: \$ 0.00
Total: \$ 330.00

Work Order

		<input checked="" type="checkbox"/>	
WO No.:	5744	Open / History:	H
WO Date:	08/13/2018	Job Status:	Completed
Sched. Date:	07/31/2018	Status Change Date:	2018.08.13 (INV)
Completed Date:	08/13/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	CU-46961978
CEES Quote:		Unit #:	2312
		Engine Make:	CUMMINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	QSL9G2 NR3
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	46961978
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CUMMINS/ ONAN
Zip:	53189	Unit Model No.:	DSHAC- 5936008
Requested By:	PATRICK PADEN	Unit Serial No.:	K080223826
Req. Telephone:		Unit Spec:	C
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Load Bank	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Kilowatts:	
Work Performed:	INSPECT UNIT; PERFORM LOAD-BANK TEST	Voltage:	
		Cable Run (ft):	0
Follow-Ups:			



Customer: Central States Diesel Generators STK#2312
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5744
 Test Date 7/31/2018

Engine Make/ Model: Cummins QSL9-G2 NR3
 Engine Spec/ Serial: 46961978
 Unit Make/ Model: Cummins DSHAC-5936008
 Unit Spec/ Serial: K080223826

Voltage: 277/480
 Amperage: 240
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	265	265.2	265.5	265.7	266	266.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	480	481	481	481
PH2	481	482	482	482	482	481
PH3	481	482	481	482	482	481
Amperage PH1	0	239	240	240	239	0
PH2	0	240	241	239	241	0
PH3	0	240	240	240	240	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	58	55	54	53	53	54
Oil Temperature						
Coolant Temperature	180°F	188°F	189°F	189°F	189°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	78°F	78°F	78°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____


Sales Order

08/13/2018

Charles Equipment

Charles Equipment Energy Systems
530 Santa Rosa Drive
Des Plaines, IL 60018
Phone: (630) 834-6000
Fax: (630) 543-4174
Email: cees@charlesequipment.com

5744



Bill To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

Ship To:

CENTRAL STATES DIESEL GENERATOR
2001 S. PRAIRIE AVE
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO
PO Number: UNIT# 2312

Notes

PERFORMED INSPECTION AND 1 HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		07/31/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3 hr	\$ 330.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

Subtotal: \$ 330.00
Sales Tax: \$ 0.00
Total: \$ 330.00