



Customer: Central States Diesel Generators STK#2312
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5744
 Test Date 7/31/2018

Engine Make/ Model: Cummins QSL9-G2 NR3
 Engine Spec/ Serial: 46961978
 Unit Make/ Model: Cummins DSHAC-5936008
 Unit Spec/ Serial: K080223826

Voltage: 277/480
 Amperage: 240
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	265	265.2	265.5	265.7	266	266.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	480	481	481	481
PH2	481	482	482	482	482	481
PH3	481	482	481	482	482	481
Amperage PH1	0	239	240	240	239	0
PH2	0	240	241	239	241	0
PH3	0	240	240	240	240	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	58	55	54	53	53	54
Oil Temperature						
Coolant Temperature	180°F	188°F	189°F	189°F	189°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	78°F	78°F	78°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____