



Customer: Central States Diesel Generators STK#2317
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5759
 Test Date 8/16/2018

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 1EZ03112
 Unit Make/ Model: Caterpillar SR4
 Unit Spec/ Serial: AFK00402

Voltage: 277/480
 Amperage: 902
 Kilowatts: 750
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	325	325	325	326	326	326
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	479	480	479	481	480	480
PH3	480	481	480	480	480	480
Amperage PH1	0	902	900	901	902	0
PH2	0	901	902	903	902	0
PH3	0	902	903	900	901	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	65	56	56	55	55	57
Oil Temperature	190°F	210°F	212°F	212°F	212°F	194°F
Coolant Temperature	185°F	194°F	194°F	195°F	195°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	81°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____