



Customer: Central States Diesel Generators STK#2320
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5762
 Test Date 8/16/2018

Engine Make/ Model: Cummins QSX15-G9 NR2
 Engine Spec/ Serial: 79303994
 Unit Make/ Model: Cummins DFEF-7081925
 Unit Spec/ Serial: D080173826

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	110.1	110.3	110.6	110.8	111.1	111.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	481	480	480	480
PH3	480	480	480	480	481	480
Amperage PH1	0	420	421	422	421	0
PH2	0	422	421	421	420	0
PH3	0	420	420	421	422	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	44	41	40	40	40	41
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	81°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____