



Customer: Central States Diesel Generators STK#2322
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5757
 Test Date 8/16/2018

Engine Make/ Model: Cummins QSB5G3 NR3
 Engine Spec/ Serial: 21814812
 Unit Make/ Model: Cummins DSFAE-5956357
 Unit Spec/ Serial: L070137845

Voltage: 277/480 (multi-voltage)
 Amperage: 120
 Kilowatts: 80
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	107.2	107.4	107.7	107.9	108.2	108.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	480	479	480
PH2	480	480	479	479	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	96	95	96	95	0
PH2	0	96	96	97	97	0
PH3	0	95	97	96	96	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	74	70	70	70	70	71
Oil Temperature						
Coolant Temperature	185°F	187°F	187°F	187°F	187°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	75°F	75°F	76°F	76°F	76°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____