



Customer: Central States Diesel Generators STK#2324
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5764
 Test Date 8/16/2018

Engine Make/ Model: Cummins QSX15-G9
 Engine Spec/ Serial: 79255586
 Unit Make/ Model: Ingersoll Rand G570
 Unit Spec/ Serial: 391849UIRC37

Voltage: 277/480
 Amperage: 604
 Kilowatts: 502
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	7212	7212.2	7212.5	7212.7	7213	7213.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	478	479	479	478	479	478
PH2	480	479	481	481	480	480
PH3	481	480	480	479	480	481
Amperage PH1	0	606	604	605	603	0
PH2	0	604	603	604	602	0
PH3	0	605	602	603	605	0
Kilowatts	0	502	502	502	502	0
Oil Pressure	OK	OK	OK	OK	OK	OK
Oil Temperature						
Coolant Temperature	OK	OK	OK	OK	OK	OK
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	82°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____