



**GENERAC**

Customer: Central States Diesel Generators  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 6138  
 Test Date 8-29-2018

Engine Make/ Model: Caterpillar 3406  
 Engine Spec/ Serial: 4JK00406  
 Unit Make/ Model: Caterpillar XQ350-3406  
 Unit Spec/ Serial: E46AMN06

Voltage: 480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	224	224	224	225	225	225
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	482	483	483	483	483
PH2	482	483	483	483	482	482
PH3	483	483	484	483	483	483
Amperage PH1	0	420	420	419	420	0
PH2	0	419	420	419	419	0
PH3	0	420	419	419	420	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	55	54	53	53	53	54
Oil Temperature						
Coolant Temperature	180°F	184°F	184°F	184°F	184°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	74°F	74°F	74°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_