



Customer: Central States Diesel Generators STK#2329
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5884
 Test Date 2018-09-05

Engine Make/ Model: Cummins NTA-855-G3
 Engine Spec/ Serial: 11930611
 Unit Make/ Model: Cummins Onan 350DFCC 99676S
 Unit Spec/ Serial: A990858373

Voltage: 277/480
 Amperage: 527
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	785.1	785.3	785.6	785.8	786.1	786.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	485	484	485	485	485
PH2	486	485	486	486	486	486
PH3	485	485	485	485	486	485
Amperage PH1	0	420	418	419	420	0
PH2	0	419	420	420	419	0
PH3	0	419	419	419	420	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	48	46	45	45	45	46
Oil Temperature	209°F	215°F	216°F	216°F	216°F	210°F
Coolant Temperature	185°F	204°F	204°F	204°F	204°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	89°F	89°F	89°F	89°F	89°F	90°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____