



Customer: Central States Diesel Generators STK#2331
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 5944
 Test Date 9-12-2018

Engine Make/ Model: Cummins QSB7-G6 NR4
 Engine Spec/ Serial: 73425990
 Unit Make/ Model: Doosan G240
 Unit Spec/ Serial: 446413UIWE51

Voltage: 480
 Amperage: 286
 Kilowatts: 190
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	11142	11142	11142	11142	11143	11143
Hertz/Cycles	45	44	44	43	43	44
Voltage PH1	478	478	478	477	477	478
PH2	477	477	478	477	477	477
PH3	477	478	477	477	477	477
Amperage PH1	0	241	242	241	241	0
PH2	0	242	241	241	242	0
PH3	0	242	241	241	242	0
Kilowatts	0	200	199	199	199	0
Oil Pressure	45	44	42	42	42	44
Oil Temperature						
Coolant Temperature	180°F	195°F	195°F	196°F	197°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	79°F	79°F	79°F	80°F	80°F	80°F

Technician Signature: _____

Customer Signature: _____