



Customer: Central States Diesel Generators #2336  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53089  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 5924  
 Test Date 2018.09.10

Engine Make/ Model: Cummins KTA19-G2  
 Engine Spec/ Serial: 37184748  
 Unit Make/ Model: Cummins/ Onan 400DFEB  
 Unit Spec/ Serial: I980795952

Voltage: 280  
 Amperage: 1390  
 Kilowatts: 400  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	307.1	307.3	307.6	307.8	308.1	308.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	209	210	209	209	209
PH2	209	210	209	209	210	209
PH3	210	209	210	209	209	210
Amperage PH1	0	1109	1110	1111	1110	0
PH2	0	1110	1108	1109	1108	0
PH3	0	1110	1108	1109	1108	0
Kilowatts	0	402	402	401	401	0
Oil Pressure	80	75	74	74	75	74
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	68°F	68°F	69°F	69°F	69°F	69°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_