



Customer: Central States Diesel Generators STK#2337
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5842
 Test Date 8/29/2018

Engine Make/ Model: Cummins 6CTA8.3G2
 Engine Spec/ Serial: 45488958
 Unit Make/ Model: Cummins Onan 150DGFA
 Unit Spec/ Serial: D970635066 Spec.87511K

Voltage: 277/480
 Amperage: 225
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1471	1471.2	1471.5	1471.7	1472	1472.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	486	485	485	485	485	486
PH2	486	486	485	485	486	486
PH3	486	486	485	485	486	486
Amperage PH1	0	179	180	179	179	0
PH2	0	180	179	180	180	0
PH3	0	179	179	180	179	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	45	44	44	43	42	43
Oil Temperature						
Coolant Temperature	190°F	208°F	210°F	210°F	210°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	72°F	73°F	73°F	73°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____