



Customer: Central States Diesel Generators #2326
 Address: _____
 City/ State/ Zip _____
 Contact: _____
 Phone: _____

R#: 5957
 Test Date 2018-09-20

Engine Make/ Model: Caterpillar C15
 Engine Spec/ Serial: AR286-4924/ FTE00994
 Unit Make/ Model: Caterpillar/ LC6
 Unit Spec/ Serial: CAT00000PC5E03663

Voltage: 480
 Amperage: 752
 Kilowatts: 500
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	205	-	-	-	206	206
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	15	158	302	421	600	0
PH2	14	158	300	423	599	0
PH3	14	157	300	423	598	0
Kilowatts	12	131	250	351	497	0
Oil Pressure	78	75	71	68	65	65
Oil Temperature						
Coolant Temperature	145°F	162°F	178°F	184°F	192°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	80°F	-	-	-	-	80°F

Cable Length: 15 _____

Cable/ Leg: 2 _____

Connection Point: Breaker _____

Technician Signature: John Colini

Customer Signature: _____