



GENERAC

Customer: Central States Diesel Generators STK#2348
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6110
 Test Date 10-3-2018

Engine Make/ Model: Cummins DCEXL0409AAD
 Engine Spec/ Serial: 73544433
 Unit Make/ Model: Cummins ONAN DSGAE-1332213
 Unit Spec/ Serial: F130525220 Spec. A

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	228.5	228.7	229	229.2	229.5	229.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	486	485	485	486	485
PH2	486	486	485	485	486	486
PH3	485	485	486	486	486	485
Amperage PH1	0	240	239	240	239	0
PH2	0	239	239	239	240	0
PH3	0	240	239	240	239	0
Kilowatts	0	201	201	201	201	0
Oil Pressure	50	46	45	44	44	47
Oil Temperature						
Coolant Temperature	185°F	188°F	188°F	188°F	188°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	75°F	76°F	76°F	76°F	76°F	76°F

Technician Signature: _____

Customer Signature: _____