



Customer: Central States Diesel Generators  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 5378  
 Test Date 6/26/2018

Engine Make/ Model: Caterpillar C15  
 Engine Spec/ Serial: G6B10608  
 Unit Make/ Model: Caterpillar  
 Unit Spec/ Serial:

Voltage: 480  
 Amperage: 602 (482 @ 1.0 PF)  
 Kilowatts: 400  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	174	174.3	174.5	174.8	175	175
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	120	241	361	482	482	0
PH2	120	241	361	482	482	0
PH3	120	241	361	482	482	0
Kilowatts	100	200	300	400	400	0
Oil Pressure	84	78	76	74	74	74
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	100°F	130°F	138°F	149°F	168°F	170°F
Man Vac./Press. L/B	N/A	N/A	N/A	N/A	N/A	N/A
Man Vac./Press. R/B	N/A	N/A	N/A	N/A	N/A	N/A
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	N/A	N/A	N/A	N/A	N/A	N/A
DC Voltage	26	26	26	26	26	26
Natural Gas Pressure	N/A	N/A	N/A	N/A	N/A	N/A
Diesel Fuel Level	REMOTE TANK SUPPLY					
Room Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	88°F	88°F	88°F	88°F	88°F	88°F

Technician Signature: Jamie Merla

Customer Signature: Patrick Paden