



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 5377
 Test Date 6/26/2018

Engine Make/ Model: Caterpillar 3406
 Engine Spec/ Serial: 4ZR07324
 Unit Make/ Model: Caterpillar
 Unit Spec/ Serial:

Voltage: 480
 Amperage: 602 (482 @ 1.0 PF)
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	315	315.3	315.5	315.8	316	316
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	120	241	361	482	482	0
PH2	120	241	361	482	482	0
PH3	120	241	361	482	482	0
Kilowatts	100	200	300	400	400	0
Oil Pressure	72	62	60	55	55	60
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	120°F	165°F	170°F	182°F	182°F	180°F
Man Vac./Press. L/B	N/A	N/A	N/A	N/A	N/A	N/A
Man Vac./Press. R/B	N/A	N/A	N/A	N/A	N/A	N/A
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	N/A	N/A	N/A	N/A	N/A	N/A
DC Voltage	26	26	26	26	26	26
Natural Gas Pressure	N/A	N/A	N/A	N/A	N/A	N/A
Diesel Fuel Level	REMOTE TANK SUPPLY					
Room Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	88°F	88°F	88°F	88°F	88°F	88°F

Technician Signature: Jamie Merla

Customer Signature: Patrick Paden