

Customer: Central States Diesel Generators STK#2298

R#: 5673

Test Date 1-11-2019

Address: 2001 S Prairie Ave.

City/ State/ Zip: Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

Engine Make/ Model: Mitsubishi 8DC9

Voltage: 277/480

Engine Spec/ Serial: 446786

Amperage: 481

Unit Make/ Model: Generac 1742520100

Kilowatts: 400

Unit Spec/ Serial: 2064996

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	190.4	190.6	190.9	191.1	191.4	191.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	480	479	479	479
PH2	480	479	480	479	479	480
PH3	480	480	479	480	479	480
Amperage PH1	0	480	481	481	480	0
PH2	0	481	480	482	481	0
PH3	0	482	483	483	482	0
Kilowatts	0	399	399	400	399	0
Oil Pressure	65	63	61	60	60	61
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	21°F	21°F	22°F	22°F	22°F	22°F

Technician Signature: Randy Pool

Customer Signature: _____