



Customer: Central States Diesel Generators STK#2318  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8173  
 Test Date 10-9-19

Engine Make/ Model: Caterpillar G3306NA  
 Engine Spec/ Serial: HCC00531  
 Unit Make/ Model: Caterpillar G3306NA  
 Unit Spec/ Serial: JCA00360

Voltage: 277/480  
 Amperage: 102  
 Kilowatts: 85 test @57KW LP  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	849.8	850	850.3	850.5	850.8	850.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	483	482	482	483	482
PH2	483	483	484	483	483	483
PH3	485	484	485	485	485	485
Amperage PH1	0	68	68	68	67	0
PH2	0	67	68	68	68	0
PH3	0	68	68	68	68	0
Kilowatts	0	57	57	57	57	0
Oil Pressure	70	68	68	68	68	68
Oil Temperature						
Coolant Temperature	180°F	184°F	184°F	184°F	184°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	64°F	64°F	64°F	64°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_