



Customer: Central States Diesel Generators STK#2319
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 6068
 Test Date 9-26-2019

Engine Make/ Model: Caterpillar G3306NA
 Engine Spec/ Serial: HCC00540
 Unit Make/ Model:
 Unit Spec/ Serial: JCA00370

Voltage: 277/480
 Amperage: 102
 Kilowatts: 85 test at 31KW
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1833.7	1834	1834.2	1834.5	1834.7	1834.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	482	482	482	482
PH2	482	482	482	482	482	482
PH3	484	484	485	484	484	484
Amperage PH1	0	37	37	38	37	0
PH2	0	38	37	37	38	0
PH3	0	37	38	37	38	0
Kilowatts	0	31	31	31	31	0
Oil Pressure	90	87	86	86	86	88
Oil Temperature						
Coolant Temperature	185°F	196°F	197°F	197°F	197°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	72°F	72°F	72°F

Technician Signature: Randy Pool

Customer Signature: _____