



Customer: Central States Diesel Generators STK#2327
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 6109
 Test Date 10-30-2018

Engine Make/ Model: John Deere 4045HF120
 Engine Spec/ Serial: CD4045B027585
 Unit Make/ Model: SDMO J100U07006724
 Unit Spec/ Serial: XM-J100U-IV-INC/45962663-001

Voltage: 277/480
 Amperage: 121
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1074.8	1075	1075.3	1075.5	1075.8	1075.9
Hertz/Cycles	63.2	62.5	62.5	62.5	62.5	63.2
Voltage PH1	479	476	477	476	476	479
PH2	480	477	476	477	476	480
PH3	479	476	477	476	477	479
Amperage PH1	0	122	121	121	121	0
PH2	0	121	122	122	122	0
PH3	0	122	122	122	122	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	42	37	36	36	36	38
Oil Temperature						
Coolant Temperature	190°F	200°F	200°F	200°F	200°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	42°F	42°F	43°F	43°F	43°F	43°F

Technician Signature: Randy Pool

Customer Signature: _____