



Customer: Central States Diesel Generators #2328
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 6221
 Test Date 2018.09.06

Engine Make/ Model: Perkins 1987/1800 AM50850
 Engine Spec/ Serial: AM50850*U201288H*
 Unit Make/ Model: Olympian D75P2
 Unit Spec/ Serial: OLY00000ENPF00687

Voltage: 120/208
 Amperage: 208
 Kilowatts: 75
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	467.9	468.1	468.4	468.6	468.9	469
Hertz/Cycles	63	60	60	60	60	63
Voltage PH1	211	210	211	211	210	211
PH2	210	211	210	211	210	210
PH3	211	210	211	211	210	211
Amperage PH1	0	207	206	207	208	0
PH2	0	208	207	207	208	0
PH3	0	208	207	207	208	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	40	35	35	35	25	38
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	195°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	68°F	68°F	69°F	69°F	69°F

Technician Signature: _____

Customer Signature: _____