

# Work Order

		<input checked="" type="checkbox"/>	
WO No.:	5817	Open / History:	H
WO Date:	08/24/2018	Job Status:	Completed
Sched. Date:	08/27/2018	Status Change Date:	2018.10.22 (I)
Completed Date:	10/22/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	CU-25244767
CEES Quote:		Unit #:	2314
		Engine Make:	CUMMINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	KTA38G4
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	25244767
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CUMMINS/ ONAN
Zip:	53189	Unit Model No.:	DFJD
Requested By:	PATRICK PADEN	Unit Serial No.:	I990978686
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	192
Perform For Type:	Customer	Tolls Paid:	6
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Load Bank	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE		
		Signed Signature:	
Brief Description:	INSPECT AND LOAD BANK FOR SALE RETEST WITH CUSTOMER WITNESS.	Kilowatts:	1000
		Voltage:	480
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Cable Run (ft):	0
Work Performed:	8-27-18 ATTEMPTED TO TEST UNIT, SEVERE OIL LEAK LEFT SIDE. 9-13-18 DRAIN COOLING SYSTEM. 9-14-18 REMOVE LEFT FRONT INTAKE MANIFOLD. FOUND DEFECTIVE OIL FEED O-RINGS ON CYLINDER 3L. 9-26-18 INSTALLED NEW OIL SUPPLY O-RINGS ON LEFT FRONT SECTION OF INTAKE MANIFOLD. INSTALLED NEW INTAKE GASKETS. FILLED COOLING SYSTEM WITH ORIGINAL COOLANT. 9-27-18 PERFORMED ONE HOUR LOAD BANK TEST. 10-4-18 (RANDY) TEMPORARY ENCLOSURE AND MUFFLER MOUNTING FOR TESTING. 10-5-18 (RANDY/TIMMY) COMPLETED TEMP INSTALL OF ENCLOSURE AND MUFFLER FOR SOUND TESTING. 10-8-18 PERFORMED LOAD TEST WITH CUSTOMER PRESENT. APPLIED VARIOUS LOADS AND CUSTOMER PERFORMED SOUND LEVEL TESTING. 10-11-18 PERFORMED AUTO START TEST PER CUSTOMER REQUEST. 10-18-18 TESTED BOTH ENGINE BLOCK HEATERS AND BATTERY CHARGER. 10-19-18 REMOVED SILENCER AND ENCLOSURE.		
Follow-Ups:			



Customer: Central States Diesel Generators STK#2314  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 5817  
 Test Date 9-27-2018

Engine Make/ Model: Cummins KTA-38-G4  
 Engine Spec/ Serial: 25244767  
 Unit Make/ Model: Cummins ONAN DFJD-3376731  
 Unit Spec/ Serial: I990978686

Voltage: 277/480  
 Amperage: 1203  
 Kilowatts: 1000  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	808.5	808.7	809	809.2	809.5	809.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	481	481	481
PH2	479	480	479	480	479	479
PH3	480	480	480	480	480	480
Amperage PH1	0	1204	1204	1202	1204	0
PH2	0	1203	1205	1204	1204	0
PH3	0	1204	1203	1204	1203	0
Kilowatts	0	1000	1000	1000	1000	0
Oil Pressure	79	70	64	63	63	68
Oil Temperature						
Coolant Temperature	180°F	183°F	184°F	184°F	184°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	55°F	56°F	56°F	57°F	57°F	58°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

5817



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2314

### Notes

ATTEMPTED TO TEST, FOUND SEVERE OIL LEAK, REPAIRED OIL LEAK, PERFORMED LOADBANK TEST,

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
mikejr	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	3916284 - SEAL, O RING	\$ 10.10	2 ea	\$ 20.20
2	Sale	4954442 - SEAL, O RING	\$ 8.60	2 ea	\$ 17.20
3	Sale	SFT/M/IL (ILLINOIS LABOR) - STRAIGHT FIELD LABOR-IL	\$ 110.00	16 hr	\$ 1,760.00
4	Sale	OT/F/IL (ILLINOIS LABOR) - NORMAL OVERTIME FIELD - IL	\$ 135.00	2 hr	\$ 270.00
5	Sale	MILEAGE/IL (NO CHARGE) - MILEAGE CHARGE - IL	\$ 0.00	576 ea	\$ 0.00
6	Sale	TOLLS (NO CHARGE) - TOLLS	\$ 0.00	18 ea	\$ 0.00
7	Sale	SFT/M/WI (RANDY) - STRAIGHT FIELD LABOR - WI	\$ 110.00	44.5 hr	\$ 4,895.00
8	Sale	OT/F/WI (RANDY) - NORMAL OVERTIME FIELD - WI	\$ 135.00	1 hr	\$ 135.00

# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

5817



This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

---

<b>Subtotal:</b>	<b>\$ 7,097.40</b>
<b>Sales Tax:</b>	<b>\$ 0.00</b>
<b>Total:</b>	<b>\$ 7,097.40</b>

# Work Order

		<input checked="" type="checkbox"/>
WO No.: 6105		Open / History: H
WO Date: 10/02/2018		Job Status: Completed
Sched. Date: 10/02/2018		Status Change Date: 2018.10.22 (I)
Completed Date: 10/23/2018		Assign To Type: Technician
Bill With Work Order:		Assign To: (RANDY POOL)
Follow Up From WO#: 0		
Customer P.O. No.:		Asset ID: VO-207118607
CEES Quote:		Unit #: 2347
		Engine Make: VOLVO
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: TAD741GE
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.: 207118607
City: WAUKESHA		Engine Spec: 868885
State: WISCONSIN		Unit Make:
Zip: 53189		Unit Model No.:
Requested By: PATRICK PADEN		Unit Serial No.:
Req. Telephone:		Unit Spec:
Req. E-mail:		Engine Hours: 0
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS		
Account #: 1121		Round Trip Miles: 0
Perform For Type: Customer		Tolls Paid: 0
Perform For:		
		Time In: 10/02/2018 02:44:00 PM
WO Type: Load Bank		Time Out: 10/02/2018 02:44:00 PM
Problem Type: INSPECT AND LOAD BANK FOR SALE		
Brief Description: INSPECT AND LOAD BANK FOR SALE		Signed Signature:
Customer Complaint:		Kilowatts:
		Voltage:
		Cable Run (ft): 0
Work Performed: 10-2-18 REMOVED DEFECTIVE FAN BELT TENSIONER. REQUESTED REPLACEMENT FROM JR. PROVIDED P/N. 10-19-18 INSTALLED NEW BELT TENSIONER. CONNECTED FUEL SUPPLY AND STARTING BATTERIES. STARTED ENGINE AND FOUND SEVERE OIL LEAK. OIL COMING FROM BREATHER. CONNECTED MANOMETER TO DIPSTICK TUBE, STARTED ENGINE TO MEASURE CRANKCASE PRESSURE. PRESSURE EXCEEDS CAPABILITY OF MANOMETER (>3PSI). POSSIBLE BROKEN OR SIEZED PISTON RINGS. CLOSE TICKET AND BILL PER PATRICK.		
Follow-Ups:		


# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6105



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT # 2347

### Notes

REMOVE AND REPLACED BELT TENSIONER

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
mikejr	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	421540 - BELT TENSIONER	\$ 373.11	1 ea	\$ 373.11
2	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	4 hr	\$ 440.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 813.11  
**Sales Tax:** \$ 0.00  
**Total:** \$ 813.11

# Work Order

		<input checked="" type="checkbox"/>	
WO No.:	6182	Open / History:	H
WO Date:	10/17/2018	Job Status:	Completed
Sched. Date:	10/17/2018	Status Change Date:	2018.10.17 (INV)
Completed Date:	10/22/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	PE-GE2036601
CEES Quote:		Unit #:	2354
		Engine Make:	PERKINS
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	NO TAG
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	CATERPILLAR
Zip:	53189	Unit Model No.:	CD100
Requested By:	PATRICK PADEN	Unit Serial No.:	2306601
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Repair	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Kilowatts:	
		Voltage:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Cable Run (ft):	0
Work Performed:	INSPECT UNIT; CHECK FLUIDS; PERFORM 1-HOUR LOAD-BANK TEST		
Follow-Ups:			



**Customer:** Central States Diesel Generators STK#2354  
**Address:** 2001 S Prairie Ave.  
**City/ State/ Zip:** Waukesha, WI 53189  
**Contact:** Patrick Paden  
**Phone:** 262-995-7655

**R#:** 6182  
**Test Date:** 10-17-2018

**Engine Make/ Model:** Generac P/N 92460 5.0L 7H22 87800866  
**Engine Spec/ Serial:** ND722999  
**Unit Make/ Model:** Caterpillar CD100  
**Unit Spec/ Serial:** 2036601

**Voltage:** 120/208  
**Amperage:** 277  
**Kilowatts:** 100  
**Power Factor:** 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
<b>Eng Hours</b>	416.1	416.3	416.6	416.8	417.1	417.2
<b>Hertz/Cycles</b>	60	60	60	60	60	60
<b>Voltage PH1</b>	208	208	208	208	208	208
<b>PH2</b>	208	207	207	207	207	208
<b>PH3</b>	207	208	208	208	208	207
<b>Amperage PH1</b>	0	277	277	276	278	0
<b>PH2</b>	0	277	277	278	278	0
<b>PH3</b>	0	277	277	278	277	0
<b>Kilowatts</b>	0	100	100	100	100	0
<b>Oil Pressure</b>	40	38	36	36	36	38
<b>Oil Temperature</b>						
<b>Coolant Temperature</b>	185°F	190°F	190°F	190°F	190°F	185°F
<b>Man Vac./Press. L/B</b>						
<b>Man Vac./Press. R/B</b>						
<b>L/B Exhaust Temp</b>						
<b>R/B Exhaust Temp</b>						
<b>Exhaust Temperature</b>						
<b>DC Voltage</b>	14.1	14.1	14.1	14.1	14.1	14.1
<b>Natural Gas Pressure</b>						
<b>Diesel Fuel Level</b>						
<b>Room Temperature</b>						
<b>Ambient Temperature</b>	41°F	41°F	41°F	41°F	41°F	42°F

**Technician Signature:** \_\_\_\_\_

**Customer Signature:** \_\_\_\_\_





Customer: Central States Diesel Generators STK#2354  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6182  
 Test Date 10-17-2018

Engine Make/ Model: Generac P/N 92460 5.0L 7H22 87800866  
 Engine Spec/ Serial: ND722999  
 Unit Make/ Model: Caterpillar CD100  
 Unit Spec/ Serial: 2036601

Voltage: 120/208  
 Amperage: 277  
 Kilowatts: 100  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	416.1	416.3	416.6	416.8	417.1	417.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	207	207	207	207	208
PH3	207	208	208	208	208	207
Amperage PH1	0	277	277	276	278	0
PH2	0	277	277	278	278	0
PH3	0	277	277	278	277	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	40	38	36	36	36	38
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	41°F	41°F	41°F	41°F	42°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6182



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2354

### Notes

INSPECT UNIT, CHECKED FLUIDS, PERFORMED LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	3.5 hr	\$ 385.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 385.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 385.00

# Work Order

		<input checked="" type="checkbox"/>	
WO No.: 6183		Open / History: H	
WO Date: 10/17/2018		Job Status: Completed	
Sched. Date: 10/08/2018		Status Change Date: 2018.10.22 (INV)	
Completed Date: 10/22/2018		Assign To Type: Technician	
Bill With Work Order:		Assign To: (RANDY POOL)	
Follow Up From WO#: 0			
Customer P.O. No.:		Asset ID: CU-73154091	
CEES Quote:		Unit #: 2344	
		Engine Make: CUMMINS	
Site: CENTRAL STATES DIESEL GENERATORS		Engine Model No.: QSL9G3 NR3	
Site_addr: 2001 S. PRAIRIE AVE.		Engine Serial No.:	
City: WAUKESHA		Engine Spec: 73154091	
State: WISCONSIN		Unit Make: DOOSAN	
Zip: 53189		Unit Model No.: G290	
Requested By: PATRICK PADEN		Unit Serial No.: 428431UGVC38	
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours: 0	
Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS			
Account #: 1121		Round Trip Miles: 0	
Perform For Type: Customer		Tolls Paid: 0	
Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)			
		Time In:	
WO Type: Load Bank		Time Out:	
Problem Type: INSPECT AND LOAD BANK FOR SALE			
Brief Description: INSPECT AND LOAD BANK FOR SALE		Signed Signature:	
		Kilowatts: 255	
Customer Complaint: PERFORM INSPECTION		Voltage: 208	
PERFORM 1-HOUR LOAD-BANK TEST		Cable Run (ft): 0	
Work Performed: 10/4/18 INSPECT UNIT; CHECK FLUIDS; PERFORM 1-HOUR LOAD-BANK TEST.			
10/8/18 -PERFORMED MAINTENANCE - CUSTOMER SUPPLIED PARTS.			
Follow-Ups:			



Customer: Central States Diesel Generators STK#2344  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-995-7655

R#: 6183  
 Test Date 10-8-2018

Engine Make/ Model: Cummins QSL9G3 NR3  
 Engine Spec/ Serial: 73154091  
 Unit Make/ Model: Doosan G290  
 Unit Spec/ Serial: 428431UGVC38

Voltage: 120/208  
 Amperage: 855  
 Kilowatts: 255  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	5341.1	5341.3	5341.6	5341.8	5342.1	5342.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	206	206	206	206	208
PH2	208	207	206	207	206	208
PH3	207	206	206	206	206	208
Amperage PH1	0	714	715	714	713	0
PH2	0	713	714	713	715	0
PH3	0	713	714	715	715	0
Kilowatts	0	255	255	255	255	0
Oil Pressure	no data	no data	no data	no data	no data	no data
Oil Temperature						
Coolant Temperature	no data	no data	no data	no data	no data	no data
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	66°F	66°F	67°F	67°F	67°F	67°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6183



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2344

### Notes

INSPECT UNIT, CHECKED FLUIDS, PERFORMED LOADBANK TEST, PERFORMED MAINTENANCE - CUSTOMER SUPPLIED PARTS


Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	6 hr	\$ 660.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 660.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 660.00

# Work Order

			
WO No.:	6189	Open / History:	H
WO Date:	10/19/2018	Job Status:	Completed
Sched. Date:	10/18/2018	Status Change Date:	
Completed Date:	10/22/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	JD-PE6068T139756
CEES Quote:		Unit #:	2358
		Engine Make:	JOHN DEERE
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	6068TF250
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	PE6068T139756
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	KATOLIGHT
Zip:	53189	Unit Model No.:	D125FGJ4
Requested By:	PATRICK PADEN	Unit Serial No.:	LM240261 76852
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Repair	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Kilowatts:	125
		Voltage:	240 (1/0)
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Cable Run (ft):	0
Work Performed:	INSPECT UNIT; CHECK FLUIDS; PERFORM 1-HOUR LOAD-BANK TEST		
Follow-Ups:			

# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6189



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2358

### Notes

INSPECT UNIT, CHECKED FLUIDS, PERFORMED LOADBANK TEST


Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 275.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 275.00

# Work Order

			
WO No.:	6190	Open / History:	H
WO Date:	10/19/2018	Job Status:	Completed
Sched. Date:	10/18/2018	Status Change Date:	2018.10.22 (I)
Completed Date:	10/22/2018	Assign To Type:	Technician
Bill With Work Order:		Assign To:	(RANDY POOL)
Follow Up From WO#:	0		
Customer P.O. No.:		Asset ID:	JD-PE6068L007861
CEES Quote:		Unit #:	2357
		Engine Make:	JOHN DEERE
Site:	CENTRAL STATES DIESEL GENERATORS	Engine Model No.:	6068HF285
Site_addr:	2001 S. PRAIRIE AVE.	Engine Serial No.:	PE6068L007861
City:	WAUKESHA	Engine Spec:	
State:	WISCONSIN	Unit Make:	KATOLIGHT
Zip:	53189	Unit Model No.:	D150FGJ4T3
Requested By:	PATRICK PADEN	Unit Serial No.:	140185-0307
Req. Telephone:		Unit Spec:	
Req. E-mail:		Engine Hours:	0
Bill To: (Invoice):	CENTRAL STATES DIESEL GENERATORS		
Account #:	1121	Round Trip Miles:	0
Perform For Type:	Customer	Tolls Paid:	0
Perform For:	CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		
		Time In:	
WO Type:	Repair	Time Out:	
Problem Type:	INSPECT AND LOAD BANK FOR SALE	Signed Signature:	
Brief Description:	INSPECT AND LOAD BANK FOR SALE	Kilowatts:	
Customer Complaint:	PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST	Voltage:	
Work Performed:	INSPECT UNIT; CHECK FLUIDS; PERFORM 1-HOUR LOAD-BANK TEST	Cable Run (ft):	0
Follow-Ups:			



# Sales Order

10/22/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

6190



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2357

### Notes

INSPECT UNIT, CHECKED FLUIDS, PERFORMED LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		10/22/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 275.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 275.00