



Customer: Central States Diesel Generators  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 5890  
 Test Date 9-6-2018

Engine Make/ Model: Caterpillar C15  
 Engine Spec/ Serial: FSE00651  
 Unit Make/ Model: Caterpillar C15  
 Unit Spec/ Serial: FSE00651

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	235.6	235.8	236.1	236.3	236.5	235.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	480	481	481
PH2	481	481	481	480	481	481
PH3	480	480	481	480	480	480
Amperage PH1	0	601	600	601	600	0
PH2	0	600	601	600	601	0
PH3	0	600	601	601	600	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	68	64	64	64	64	66
Oil Temperature						
Coolant Temperature	185°F	189°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25	25	25	25	25	25
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	68°F	68°F	68°F	69°F	69°F	69°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_